

Operating Records of Nuclear Power Plants in November

Power Plant	Reactor Type	Gross Capacity (MWe)	Availability Factor		Capacity Factor		Remarks
			Operating hours [h]	[%]	Generated output [MWh]	[%]	
Tokai-Daini (II)	BWR	1100	720	100.0	803,797	101.5	
Tsuruga-1	BWR	357	720	100.0	258,705	100.6	
Tsuruga-2	PWR	1160	720	100.0	846,654	101.4	
Tomari-1	PWR	579	629	87.4	352,301	84.5	Shutdown due to periodic inspection. (14.Aug.-4.Nov.)
Tomari-2	PWR	579	720	100.0	429,213	103.0	
Onagawa-1	BWR	524	0	0.0	0	0.0	Shutdown due to periodic inspection. (8.Sep.-)
Onagawa-2	BWR	825	720	100.0	600,477	101.1	
Onagawa-3	BWR	825	720	100.0	613,958	103.4	
Fukushima I-1	BWR	460	0	0.0	0	0.0	Shutdown due to periodic inspection. (20.Nov.2002-)
Fukushima I-2	BWR	784	660	91.7	492,072	87.2	Manual shutdown due to recirculation pump trouble. (29.Sep.-3.Nov.)
Fukushima I-3	BWR	784	0	0.0	0	0.0	Shutdown due to periodic inspection. (9.Aug.-)
Fukushima I-4	BWR	784	720	100.0	564,478	100.0	
Fukushima I-5	BWR	784	216	30.0	165,619	29.3	Shutdown due to periodic inspection. (10.Nov.-)
Fukushima I-6	BWR	1100	605	84.0	632,119	79.8	Shutdown due to periodic inspection. (30.Sep.2003-6.Nov.)
Fukushima II-1	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (29.Sep.-)
Fukushima II-2	BWR	1100	720	100.0	799,596	101.0	
Fukushima II-3	BWR	1100	720	100.0	797,620	100.7	
Fukushima II-4	BWR	1100	645	89.6	686,150	86.6	Shutdown due to periodic inspection. (1.Feb.2003-4.Nov.)
Kashiwazaki Kariwa-1	BWR	1100	720	100.0	807,880	102.0	
Kashiwazaki Kariwa-2	BWR	1100	720	100.0	806,700	101.9	
Kashiwazaki Kariwa-3	BWR	1100	720	100.0	802,840	101.4	
Kashiwazaki Kariwa-4	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (7.Aug.-)
Kashiwazaki Kariwa-5	BWR	1100	720	100.0	804,930	101.6	
Kashiwazaki Kariwa-6	ABWR	1356	720	100.0	1,008,004	103.2	
Kashiwazaki Kariwa-7	ABWR	1356	500	69.4	646,590	66.2	Automatic shutdown due to earthquake. (4-13.Nov.)
Hamaoka-1	BWR	540	0	0.0	0	0.0	Shutdown due to periodic inspection. (26.Apr.2002-)
Hamaoka-2	BWR	840	0	0.0	0	0.0	Shutdown due to periodic inspection. (21.Feb.-)
Hamaoka-3	BWR	1100	720	100.0	800,262	101.0	
Hamaoka-4	BWR	1137	0	0.0	0	0.0	Shutdown due to periodic inspection. (29.Sep.-)
Shika-1	BWR	540	154	21.4	65,826	16.9	Shutdown due to periodic inspection. (11.Sep.-25.Nov.)
Mihama-1	PWR	340	0	0.0	0	0.0	Shutdown due to urgent safety inspection. (5.Sep.-)
Mihama-2	PWR	500	33	4.6	5,882	1.6	Shutdown due to urgent safety inspection. (13.Aug.-29.Nov.)
Mihama-3	PWR	826	0	0.0	0	0.0	Shutdown due to periodic inspection. (14.Aug.-)
Takahama-1	PWR	826	720	100.0	620,489	104.3	
Takahama-2	PWR	826	720	100.0	618,246	104.0	
Takahama-3	PWR	870	720	100.0	645,038	103.0	
Takahama-4	PWR	870	720	100.0	647,619	103.4	
Ohi-1	PWR	1175	720	100.0	852,786	100.8	
Ohi-2	PWR	1175	720	100.0	860,492	101.7	
Ohi-3	PWR	1180	0	0.0	0	0.0	Shutdown due to periodic inspection. (20.Apr.-)
Ohi-4	PWR	1180	611	84.9	705,979	83.1	Shutdown due to periodic inspection. (25.Sep.-5.Nov.)
Shimane-1	BWR	460	720	100.0	338,287	102.1	
Shimane-2	BWR	820	0	0.0	0	0.0	Shutdown due to periodic inspection. (7.Sep.-)
Ikata-1	PWR	566	0	0.0	0	0.0	Shutdown due to periodic inspection. (5.Sep.-)
Ikata-2	PWR	566	720	100.0	405,131	99.4	
Ikata-3	PWR	890	720	100.0	667,531	104.2	
Genkai-1	PWR	559	720	100.0	412,174	102.4	
Genkai-2	PWR	559	720	100.0	414,616	103.0	
Genkai-3	PWR	1180	720	100.0	870,701	102.5	
Genkai-4	PWR	1180	720	100.0	862,393	101.5	
Sendai-1	PWR	890	720	100.0	646,920	101.0	
Sendai-2	PWR	890	457	63.5	410,506	64.1	Shutdown due to periodic inspection. (20.Nov.-)
Total/Average (Previous Month)		45742 (45742)	25,390 (21,096)	67.8% (54.5)	23,770,581 (19,930,470)	72.2% (58.6)	